

Southern California Edison
Circle City and Mira Loma-Jefferson PTC A.15-12-007

DATA REQUEST SET A1512007 ED-SCE-16

To: ENERGY DIVISION

Prepared by: Paul McCabe, P.E.

Title: Project Manager - Grid Modernization, Planning, & Technology

Dated: 12/27/2017

Question 18:

Regarding SCE Response to Data Request 15, Question 7:

Provide all known developments over the last 5 years that have contributed to load, including the approximate load addition for each development.

Response to Question 18:

SCE does not actively track past load additions on an individual project basis once they have been installed and provided electrical service and thus that information is not available. SCE does not track forecast versus actual load for individual routine-type projects, rather, SCE captures the impact of these types of projects through when they aggregated together through the review of recorded historical load data and then incorporates that information when developing forecasts for circuit and substations.